

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7272-0447:114 Page 1 of 1

**CATEGORY:** Photoelectric Smoke Detector

**LISTEE:** ESL/Sentrol, 12345 SW Leveton Drive, Tualatin, OR 97062  
Contact: Gene Hukkanen (503) 691-7369

**DESIGN:** Models 611U, 611UD, 611UT, 611UA and 611UAT. Model 611UD is suitable for installation in air ducts and in areas having an air velocity of up to 2000 fpm. Refer to listee's printed installation instructions for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as photoelectric smoke detectors for use with separately listed compatible control units and Models 601 and 602 series bases (CSFM Listing No. 7300-0447:115). Models 611UA and 611UAT are intended for use with ADT Model UNIMODE 4520 control unit (CSFM Listing No. 7165-0085:048).

**NOTE:** Formerly 7257-0447:114



---

This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **APRIL 2, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO**, Supervising Deputy  
Program Manager